

### **FEATURES:**

- ONE PIECE COMPRESSION MOLDED ENCLOSED AND GASKETED HOUSING
- ONE WATERTIGHT HUB PROVIDED
- FIBERGLASS REINFORCED POLYESTER HOUSING
- DIFFUSER OF HIGH IMPACT ACRYLIC / DR MATERIAL
- POST PAINTED HIGH REFLECTANCE POWDER COAT FINISH ON STEEL REFLECTOR; AVAILABLE WITH SPECULAR REFLECTOR ADD ON
- ZERO OR MINUS 20 DEGREE BALLASTS AVAILABLE
- MOUNTING BRACKETS FURNISHED FOR EASY INSTALLATION
- AVAILABLE WITH TAMPER RESISTANT SCREWS
- NASF/ANSI STANDARD 2 (FOOD EQUIPMENT), NEMA 4X AND IP67 RATED

UNION MADE IN THE USA.

## **ORDERING:**

NOMINAL LENGTH	LAMPS	CATALOG NUMBER
4'	4-FO32	195-*-448T8
4'	6-FO32	195-*-648T8
4'	4-F54	195-*-448T5-HO
4'	6-F54	195-*-648T5-HO

\* INSERT "R" FOR SYMMETRICAL SPECULAR REFLECTOR INSERT VOLTAGE AT END OF CATALOG NUMBER

## **NOTES:**

- 1. ALSO AVAILABLE IN T5 STANDARD OUTPUT
- 2. AVAILABLE WITH UL LISTED EMERGENCY BALLAST FOR ENCLOSED AND GASKETED FIXTURES.
- 3. FIXTURE LENGTHS ARE NON-STANDARD
- 4. OPTIONAL LENS TETHERS (2 EACH)

MANUFACTURING 1715 KIBBY ROAD - MERCED - CALIFORNIA - 95341 (209) 723-9120 - FAX: (209) 723-9131



# SERIES 195

### **BACK DETAIL**

— 4'=51.38" 8'=100.38" ————————————————————————————————————

#### NOTE

All fixtures must be installed, wired and grounded in accordance with the National Electric Code and all other applicable codes.

### !!! WARNING !!!

RISK OF FIRE OR ELECTRICAL SHOCK. ELECTRICAL PARTS MAY BE DAMAGED WHEN DRILLING OR USING "TEK" SCREWS FOR INSTALLATION OF MOUNTING HARDWARE. CHECK ENCLOSED WIRING AND COMPONENTS. USE CAUTION WHEN DRILLING "TEK" SCREWS INTO A BLIND AREA. TO PREVENT WIRING DAMAGE DO NOT EXPOSE WIRING TO SHARP EDGES.

